

Portable Audit for HDSB Round 127



School	Portable Number	Region	Round 127 Inspection Date	Pinchin Inspector	Proposed Round 128 Inspection Date	Moisture/Mould found?	Other Deficiency	Location of Condition	Comments from Round 127 Inspection
Anne J. Macarthur P.S.	HBL216	NORTH	7/18/2024	Serena Romito	September 2024	No	Yes		2 damaged vinyl floor tiles near door.
Anne J. Macarthur P.S.	HBL221	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Anne J. Macarthur P.S.	HB111	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Anne J. Macarthur P.S.	HB061	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Anne J. Macarthur P.S.	HBL202	NORTH	7/18/2024	Serena Romito	September 2024	Yes	Yes	HVAC	Level 1 - Wet subfloor under vinyl floor tile. Check that HVAC condensate line is draining properly.
Anne J. Macarthur P.S.	HBL203	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Anne J. Macarthur P.S.	HBL204	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Anne J. Macarthur P.S.	HBL205	NORTH	7/18/2024	Serena Romito	September 2024	Yes	Yes	HVAC	Level 1 - Wet subfloor under vinyl floor tile. Check that HVAC condensate line is draining properly.
Anne J. Macarthur P.S.	HBL232	NORTH	7/18/2024	Serena Romito	September 2024	Yes	Yes	HVAC	Level 1 - Wet subfloor under vinyl floor tile. Check that HVAC condensate line is draining properly.
Anne J. Macarthur P.S.	HBL233	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Boyne P.S.	HBL106	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Boyne P.S.	HB208	NORTH	7/18/2024	Serena Romito	September 2024	Yes	Yes	Roof/Wall	Level 1 - Water stained ceiling tile and wet drywall wall due to roof leak or damaged roof flashing. No caulking on condensate line.
Boyne P.S.	HB033	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Boyne P.S.	HBL241	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Boyne P.S.	HB028	NORTH	7/18/2024	Serena Romito	September 2024	No	Yes		Approximately 10 damaged vinyl floor tiles
Boyne P.S.	HBL226	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Boyne P.S.	HBL251	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Boyne P.S.	HBL253	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Boyne P.S.	HB152	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Boyne P.S.	HB015	NORTH	7/18/2024	Serena Romito	September 2024	No	No		Screw holes near railing. Approximately 10 damaged vinyl floor tiles.
Boyne P.S.	HBL254	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Boyne P.S.	HBL252	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Boyne P.S.	HBL291	NORTH	7/18/2024	Serena Romito	September 2024	No	Yes		Approximately 5 square feet of damaged vinyl plank flooring.
Boyne P.S.	HBL292	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Boyne P.S.	HBL293	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Boyne P.S.	HB165	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Boyne P.S.	HBL259	NORTH	7/18/2024	Serena Romito	September 2024	No	No		NSMOMO
Boyne P.S.	HB050	NORTH	7/18/2024	Serena Romito	September 2024	No	Yes		Detached skirting.
Bruce Trail P.S.	HBL206	NORTH	2024-07-18	Kim Ramos	September 2024	Yes	Yes	HVAC/Door	Level 1 - Approximately 9 square feet of wet floor tile at the entrance to the portable and 3 square feet to the right of the HVAC unit. One square foot of wet drywall at the bottom left of front door. Inspect HVAC flashing. Repair door weather stripping.
Bruce Trail P.S.	HBL262	NORTH	7/18/2024	Kim Ramos	September 2024	No	No		NSMOMO
Bruce Trail P.S.	HB075	NORTH	7/18/2024	Kim Ramos	September 2024	No	No		NSMOMO
Bruce Trail P.S.	HB181	NORTH	7/18/2024	Kim Ramos	September 2024	Yes	Yes	Door	Level 1 - One square foot of wet drywall at the bottom of both sides of front door. Repair door weather stripping.
Bruce Trail P.S.	HB103	NORTH	2024-07-19	Kim Ramos	September 2024	Yes	Yes	HVAC/Door	Level 1 - Approximately 25 square feet of wet floor tile around HVAC unit and 7 square feet at the front door. Two square feet of wet drywall to the bottom right of front door and 6 square feet at the baseboard along the SE wall. Inspect HVAC condensate d
Bruce Trail P.S.	HB110	NORTH	7/18/2024	Kim Ramos	September 2024	Yes	Yes	HVAC/Door	Level 1 - Approximately 27 square feet of wet floor tile around HVAC unit and 4 square feet at the front door. One linear foot of wet drywall wall at the center seam on the NW wall. Inspect HVAC condensate draining properly. Repair door weather stripping
Bruce Trail P.S.	HB046	NORTH	7/18/2024	Kim Ramos	September 2024	Yes	No	HVAC/Door	Level 1 - One square foot of wet drywall wall on both sides of HVAC unit and to the bottom left of the door. Approximately 7 square feet of wet floor tile around HVAC unit and 8 square feet at front door. Inspect HVAC condensate draining properly. Repair
Bruce Trail P.S.	HB114	NORTH	7/18/2024	Kim Ramos	September 2024	Yes	No	Door	Level 1 - 7 square feet of wet floor tile at the front entrance and 13 square feet at NE corner of portable. Two linear feet of wet wooden toe kick plate on cabinet at NE corner of portable. Repair door weather stripping.

Bruce Trail P.S.	HB062	NORTH	2024-07-20	Kim Ramos	September 2024	Yes	No	HVAC/Door	Level 1 - Approximately 13 square feet of wet floor tile at front door and 29 square feet around the HVAC unit. Four square feet of wet drywall at the bottom right of the front door. Inspect HVAC condensate draining properly. Repair door weather stripping
Bruce Trail P.S.	HB115	NORTH	7/18/2024	Kim Ramos	September 2024	No	No		NSMOMO. Limited access to walls due to contents.
Bruce Trail P.S.	HBL229	NORTH	7/18/2024	Kim Ramos	September 2024	No	Yes		Screw hole in cladding near stairs and below HVAC louvre .Damaged downspout.
Bruce Trail P.S.	HBL107	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Chris Hadfield P.S.	HBL266	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Chris Hadfield P.S.	HBL265	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Chris Hadfield P.S.	RM A10	NORTH	7/25/2024	Serena Romito	September 2024	No	No		Unable to connect with custodian. No access to interior. Exterior NSMOMO.
Chris Hadfield P.S.	RM A09	NORTH	7/25/2024	Serena Romito	September 2024	No	No		Unable to connect with custodian. No access to interior. Exterior NSMOMO.
Chris Hadfield P.S.	RM A08	NORTH	7/25/2024	Serena Romito	September 2024	No	No		Unable to connect with custodian. No access to interior. Exterior NSMOMO.
Chris Hadfield P.S.	RM A07	NORTH	7/25/2024	Serena Romito	September 2024	No	No		Unable to connect with custodian. No access to interior. Exterior NSMOMO.
Chris Hadfield P.S.	RM A06	NORTH	7/25/2024	Serena Romito	September 2024	No	No		Unable to connect with custodian. No access to interior. Exterior NSMOMO.
Chris Hadfield P.S.	RM A05	NORTH	7/25/2024	Serena Romito	September 2024	No	No		Unable to connect with custodian. No access to interior. Exterior NSMOMO.
Chris Hadfield P.S.	RM A04	NORTH	7/25/2024	Serena Romito	September 2024	No	No		Unable to connect with custodian. No access to interior. Exterior NSMOMO.
Chris Hadfield P.S.	RM A03	NORTH	7/25/2024	Serena Romito	September 2024	No	No		Unable to connect with custodian. No access to interior. Exterior NSMOMO.
Chris Hadfield P.S.	RM A02	NORTH	7/25/2024	Serena Romito	September 2024	No	No		Unable to connect with custodian. No access to interior. Exterior NSMOMO.
Chris Hadfield P.S.	RM A01	NORTH	7/25/2024	Serena Romito	September 2024	No	No		Unable to connect with custodian. No access to interior. Exterior NSMOMO.
Craig Kielburger S.S.	HB128	NORTH	7/15/2024	Kim Ramos	September 2024	Yes	Yes	Windows/Doors	Level 3 - Less than one square foot of impacted wood stud. Wet drywall and vinyl floor tiles around doors and windows. Inspect door and window flashing.
Craig Kielburger S.S.	HB113	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HB147	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HB132	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HB073	NORTH	7/23/2024	Serena Romito	September 2024	Yes	Yes	Window	Level 1 - Wet drywall around window and water damage window trim both windows. Degraded window caulking.
Craig Kielburger S.S.	HB143	NORTH	7/23/2024	Serena Romito	September 2024	No	Yes		4 Damaged vinyl floor tiles.
Craig Kielburger S.S.	HB133	NORTH	7/23/2024	Serena Romito	September 2024	No	Yes		12 Damaged vinyl floor tiles.
Craig Kielburger S.S.	HB203	NORTH	7/23/2024	Serena Romito	September 2024	No	Yes		Missing sheathing rear side.
Craig Kielburger S.S.	HB134	NORTH	7/23/2024	Serena Romito	September 2024	Yes	Yes	Window	Level 1 - Wet drywall around window. Inspect window flashing when wall open. Vinyl floor tiles curling sporadically throughout portable.
Craig Kielburger S.S.	HB057	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HB159	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HBL014	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HBL015	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HB125	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HBL084	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HB029	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HB140	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HB136	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HBL098	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HBL288	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HBL289	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HBL290	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HBL312	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Craig Kielburger S.S.	HBL313	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
E.W. Foster's P.S.	HB189	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Escarpment View P.S.	HBL090	NORTH	8/19/2024	Evan Faubert	September 2024	No	No		NSMOMO
Escarpment View P.S.	HBL103	NORTH	8/19/2024	Evan Faubert	September 2024	No	No		NSMOMO
Escarpment View P.S.	HBL104	NORTH	8/19/2024	Evan Faubert	September 2024	No	No		NSMOMO
Escarpment View P.S.	HB144	NORTH	8/19/2024	Evan Faubert	September 2024	Yes	No	Walls	Level 1: Two water stained ceiling tiles. Approximately 70 square feet of wet drywall walls at baseboard height at North, East and West walls.
Escarpment View P.S.	HB005	NORTH	8/19/2024	Evan Faubert	September 2024	Yes	No	Walls	Level 1: Approximately 30 square feet of wet drywall walls at baseboard height at North and East Walls.
Escarpment View P.S.	HB089	NORTH	8/19/2024	Evan Faubert	September 2024	No	No		NSMOMO
Escarpment View P.S.	HBL082	NORTH	8/19/2024	Evan Faubert	September 2024	No	No		NSMOMO
Escarpment View P.S.	HBL088	NORTH	8/19/2024	Evan Faubert	September 2024	No	No		NSMOMO
Escarpment View P.S.	HBL089	NORTH	8/19/2024	Evan Faubert	September 2024	No	No		NSMOMO
Escarpment View P.S.	HBL083	NORTH	8/19/2024	Evan Faubert	September 2024	No	No		NSMOMO
Escarpment View P.S.	HB056	NORTH	8/19/2024	Evan Faubert	September 2024	No	No		NSMOMO
Ethel Gardner P.S.	HB049	NORTH	6/20/2024	Serena Romito	September 2024	No	Yes		Hole in sheathing near conduits

Ethel Gardner P.S.	HBL212	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
Ethel Gardner P.S.	HBL207	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
Ethel Gardner P.S.	HBL263	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
Ethel Gardner P.S.	HBL101	NORTH	6/20/2024	Serena Romito	September 2024	No	Yes		One inch gap between door threshold and exterior wall
Ethel Gardner P.S.	HBL240	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
Ethel Gardner P.S.	HBL335	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
Glen Williams P.S.	HB184	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
Glen Williams P.S.	HB178	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
Hawthorne Village P.S.	RM301	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Hawthorne Village P.S.	RM302	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Hawthorne Village P.S.	RM303	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Hawthorne Village P.S.	RM304	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Hawthorne Village P.S.	RM305	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Hawthorne Village P.S.	RM306	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Hawthorne Village P.S.	RM307	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Hawthorne Village P.S.	RM308	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Hawthorne Village P.S.	RM309	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Hawthorne Village P.S.	RM310	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Irma Coulson P.S.	HBL246	NORTH	7/24/2024	Serena Romito	September 2024	No	No		NSMOMO
Irma Coulson P.S.	HBL245	NORTH	7/24/2024	Serena Romito	September 2024	No	No		NSMOMO
Irma Coulson P.S.	HBL244	NORTH	7/24/2024	Serena Romito	September 2024	No	No		NSMOMO
Irma Coulson P.S.	HB142	NORTH	7/24/2024	Serena Romito	September 2024	No	No		NSMOMO
Irma Coulson P.S.	HBL242	NORTH	7/24/2024	Serena Romito	September 2024	No	No		NSMOMO
Irma Coulson P.S.	HB081	NORTH	7/24/2024	Serena Romito	September 2024	No	No		NSMOMO
Irma Coulson P.S.	HB150	NORTH	7/24/2024	Serena Romito	September 2024	No	Yes		Approximately 8 square feet of interior ripped drywall paper
Irma Coulson P.S.	HB204	NORTH	7/24/2024	Serena Romito	September 2024	No	No		NSMOMO
Irma Coulson P.S.	HBL111	NORTH	7/24/2024	Serena Romito	September 2024	No	No		NSMOMO
Irma Coulson P.S.	HB146	NORTH	7/24/2024	Serena Romito	September 2024	No	No		NSMOMO
Irma Coulson P.S.	HB009	NORTH	7/24/2024	Serena Romito	September 2024	No	Yes		Approximately 30 damaged vinyl floor tiles.
J.M. Denyes P.S.	HBL317	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
J.M. Denyes P.S.	HBL318	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Milton District H.S.	HB093	NORTH	7/25/2024	Serena Romito	September 2024	No	Yes		Approximately 20 damaged vinyl floor tiles.
Milton District H.S.	HB041	NORTH	7/25/2024	Serena Romito	September 2024	No	Yes		Damaged rear eaves.
Milton District H.S.	HBL223	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Milton District H.S.	HB069	NORTH	7/25/2024	Serena Romito	September 2024	No	Yes		Door knob key hole blocked with broken key.
Milton District H.S.	HBL001	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Milton District H.S.	HBL002	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Milton District H.S.	HBL100	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Milton District H.S.	HB168	NORTH	7/25/2024	Serena Romito	September 2024	Yes	Yes	Roof	Level 1 - 2 water stained ceiling tiles.
Milton District H.S.	HB035	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Milton District H.S.	HB036	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Milton District H.S.	HB034	NORTH	7/25/2024	Serena Romito	September 2024	No	Yes		Rear eaves damaged. Approximately 5 damaged vinyl floor tiles. Baseboard detached from rear wall.
P.L. Robertson P.S.	HB004	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
P.L. Robertson P.S.	HB027	NORTH	6/20/2024	Serena Romito	September 2024	No	Yes		No caulking condensate line.
P.L. Robertson P.S.	HB021	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
P.L. Robertson P.S.	HB030	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
P.L. Robertson P.S.	HB016	NORTH	6/20/2024	Serena Romito	September 2024	No	Yes		No caulking condensate line.
P.L. Robertson P.S.	HB022	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
P.L. Robertson P.S.	HB039	NORTH	6/20/2024	Serena Romito	September 2024	No	Yes		Screw holes at front left corner. Hole in sheathing left side. Condensate line no caulking. Screw holes around light. Approximately 20 damaged vinyl floor tiles.
P.L. Robertson P.S.	HBL091	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
P.L. Robertson P.S.	HBL228	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
P.L. Robertson P.S.	HBL257	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
P.L. Robertson P.S.	HB179	NORTH	6/20/2024	Serena Romito	September 2024	No	Yes		Hole in sheathing right side. No caulking around condensate line. Screw holes near railing.
P.L. Robertson P.S.	HBL110	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
Rattlesnake Point P.S.	HBL219	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Rattlesnake Point P.S.	HBL339	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
Rattlesnake Point P.S.	HBL338	NORTH	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO

Sam Sherrat P.S.	HB082	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Sam Sherrat P.S.	HB083	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Sam Sherrat P.S.	HBL099	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Sam Sherrat P.S.	HB032	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Sam Sherrat P.S.	HBL297	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Sam Sherrat P.S.	HBL296	NORTH	7/23/2024	Serena Romito	September 2024	No	No		NSMOMO
Silver Creek P.S.	HBL336	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
Tiger Jeet Singh P.S.	HBL079	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
Tiger Jeet Singh P.S.	HBL013	NORTH	6/20/2024	Serena Romito	September 2024	No	Yes		Screw holes in corners.
Tiger Jeet Singh P.S.	HB095	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
Tiger Jeet Singh P.S.	HB187	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
Tiger Jeet Singh P.S.	HB116	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
Tiger Jeet Singh P.S.	HB109	NORTH	6/20/2024	Serena Romito	September 2024	No	No		NSMOMO
Tiger Jeet Singh P.S.	HB063	NORTH	6/20/2024	Serena Romito	September 2024	No	Yes		Screw holes near door and on front corners.
Tiger Jeet Singh P.S.	HB126	NORTH	6/20/2024	Serena Romito	September 2024	No	Yes		Degraded window caulking. Screw holes near door behind railing.
Viola Desmond P.S.	HBL270	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL271	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL272	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL273	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL274	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL275	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL276	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL277	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL278	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL279	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL280	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL281	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL282	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL283	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL284	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL285	NORTH	7/5/2024	Serena Romito	September 2024	No	Yes		Degraded window caulking.
Viola Desmond P.S.	HBL286	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
Viola Desmond P.S.	HBL287	NORTH	7/5/2024	Serena Romito	September 2024	No	No		NSMOMO
W.I. Dick P.S.	HB183	NORTH	7/24/2024	Serena Romito	September 2024	No	No		NSMOMO
W.I. Dick P.S.	HB002	NORTH	7/24/2024	Serena Romito	September 2024	No	No		NSMOMO
W.I. Dick P.S.	HB007	NORTH	7/24/2024	Serena Romito	September 2024	No	No		NSMOMO
Alton Village P.S.	HBL225	WEST	2024-07-03	Erin Zylstra	September 2024	Yes	Yes	HVAC	Level 1 - Approximately 15 sq feet of wet floor tile around HVAC unit
Alton Village P.S.	HBL237	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		NSMOMO
Alton Village P.S.	HBL238	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		NSMOMO
Alton Village P.S.	HBL239	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		NSMOMO
Alton Village P.S.	HBL234	WEST	7/26/2024	Serena Romito	September 2024	No	No		NSMOMO
Alton Village P.S.	HBL235	WEST	2024-07-03	Erin Zylstra	September 2024	Yes	Yes	HVAC	Level 1 - Approximately 20 sq feet of wet floor tile around HVAC unit
Alton Village P.S.	HBL236	WEST	7/26/2024	Serena Romito	September 2024	No	No		NSMOMO
Brant Hills P.S.	HB169	WEST	2023-07-08	Erin Zylstra	September 2024	Yes	Yes	HVAC	Level 1 - Approximately 18 sq feet of wet floor tile around HVAC unit
Bruce T. Lindley	HBL332	WEST	2023-07-08	Erin Zylstra	September 2024	Yes	Yes	Door	Level 1 - Less than 1 sq foot of wet drywall wall to right of door. Thick dust accumulations above HVAC unit
Central P.S.	HBL230	WEST	2023-07-08	Erin Zylstra	September 2024	No	No		NSMOMO
Central P.S.	HBL231	WEST	2023-07-08	Erin Zylstra	September 2024	No	No		NSMOMO
Dr. Charles Best P.S.	HB139	WEST	7/26/2024	Serena Romito	September 2024	No	Yes		Degraded door caulking. 1 broken ceiling tile.
Dr. Frank Hayden S.S.	HB059	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		NSMOMO
Dr. Frank Hayden S.S.	HB120	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		NSMOMO
Dr. Frank Hayden S.S.	HB172	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		NSMOMO
Dr. Frank Hayden S.S.	HB092	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		NSMOMO
Dr. Frank Hayden S.S.	HB137	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		NSMOMO
Dr. Frank Hayden S.S.	HB207	WEST	2024-07-03	Erin Zylstra	September 2024	No	Yes		Less than 1 sq foot of deteriorating drywall wall to right of door
Dr. Frank Hayden S.S.	HB151	WEST	2024-07-03	Erin Zylstra	September 2024	No	Yes		Three damaged floor tiles at entrance to portable
Glenview P.S.	HB024	WEST	2023-07-08	Erin Zylstra	September 2024	No	Yes		Exposed hole at conduit. HVAC condensate hose pouring into exterior cladding.
Glenview P.S.	HB0316	WEST	2023-07-08	Erin Zylstra	September 2024	No	Yes		Exposed hole at conduit at rear of portable

Glenview P.S.	HB166	WEST	2023-07-08	Erin Zylstra	September 2024	No	Yes		Caulking degraded around window. Door not sealed properly
Glenview P.S.	HB122	WEST	2023-07-08	Erin Zylstra	September 2024	No	No		NSMOMO
Glenview P.S.	HB148	WEST	2023-07-08	Erin Zylstra	September 2024	No	No		NSMOMO
J.W. Singleton Ed. Ctr.	HB119	WEST	7/26/2024	Serena Romito	September 2024	Yes	Yes	Wall, door	Level 1 - wet drywall due to damaged patch in sheathing on rear wall and rusted wall flashing near door. Screw holes and degraded caulking around HVAC louvre.
J.W. Singleton Ed. Ctr.	HB118	WEST	7/26/2024	Serena Romito	September 2024	No	Yes		Damaged door sill
J.W. Singleton Ed. Ctr.	HB117	WEST	7/26/2024	Serena Romito	September 2024	No	No		NSMOMO
J.W. Singleton Ed. Ctr.	HB003	WEST	7/26/2024	Serena Romito	September 2024	No	No		NSMOMO
John T. Tuck P.S.	HBL220	WEST	7/26/2024	Serena Romito	September 2024	No	Yes		Degraded window caulking.
John T. Tuck P.S.	HB173	WEST	2024-07-03	Erin Zylstra	September 2024	No	Yes		Two broken floor tile at entrance with exposed subfloor
John T. Tuck P.S.	HB157	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		NSMOMO
John T. Tuck P.S.	HB156	WEST	2024-07-03	Erin Zylstra	September 2024	Yes	Yes	Door	Level 1 - Approximately 6 sq feet of wet floor tile at entrance. Repair door weather stripping.
John T. Tuck P.S.	HB064	WEST	7/26/2024	Serena Romito	September 2024	Yes	Yes	HVAC	Level 1 - wet drywall around HVAC. Inspect HVAC flashing when wall open.
Kilbride P.S.	HB074	WEST	7/25/2024	Serena Romito	September 2024	No	No		NSMOMO
King's Road P.S.	HB195	WEST	2023-07-08	Erin Zylstra	September 2024	Yes	Yes	Door	Level 1 - Approximately 2 sq feet of wet drywall wall at bottom of door. Repair door weather stripping.
King's Road P.S.	HB196	WEST	2023-07-08	Erin Zylstra	September 2024	Yes	Yes	Walls	Level 1 - Approximately 54 sq feet of wet drywall wall throughout. Inspect wall flashing.
King's Road P.S.	HB127	WEST	2023-07-08	Erin Zylstra	September 2024	Yes	Yes	Door	Level 1 - Approximately 8 sq feet of wet drywall at bottom of door. Repair door weather stripping.
Orchard Park P.S.	HB066	WEST	2023-07-08	Erin Zylstra	September 2024	No	No		NSMOMO
Paul A. Fisher	HB037	WEST	7/26/2024	Serena Romito	September 2024	No	Yes		Degraded door caulking. 1 broken ceiling tile.
Paul A. Fisher	HBL247	WEST	7/26/2024	Serena Romito	September 2024	No	Yes		4 damaged vinyl floor tiles.
Paul A. Fisher	HB162	WEST	7/26/2024	Serena Romito	September 2024	No	Yes		Approximately 10 damaged floor tiles throughout. Condensate line not draining properly.
Pauline Johnson P.S.	HBL222	WEST	2024-07-03	Erin Zylstra	September 2024	Yes	Yes	Door	Level 1 - Less than 1 sq foot of wet drywall wall at bottom left of door. Repair door weather stripping. Screw holes in cladding at SW corner
Pauline Johnson P.S.	HB102	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		NSMOMO
Tom Thomson P.S.	HB124	WEST	2024-07-03	Erin Zylstra	September 2024	Yes	Yes	HVAC	Level 1 - Approximately 3 sq feet of wet floor tile around HVAC unit. Inspect HVAC condensate hose draining properly.
Tom Thomson P.S.	HB031	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		NSMOMO
Tom Thomson P.S.	HB105	WEST	2024-07-03	Erin Zylstra	September 2024	No	Yes		Degraded caulking around HVAC louvre and conduits
Tom Thomson P.S.	HB098	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		NSMOMO
Tom Thomson P.S.	HBL109	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		NSMOMO
Tom Thomson P.S.	HB141	WEST	2024-07-03	Erin Zylstra	September 2024	Yes	Yes	Door	Level 1 - Approximately 6 sq feet of wet floor tile at entrance. Repair door weather stripping. Approximately 10 damaged floor tiles throughout and split caulking at conduits.
Tom Thomson P.S.	HB012	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		Approximately 10 damaged floor tiles throughout
Tom Thomson P.S.	HB051	WEST	2024-07-03	Erin Zylstra	September 2024	No	No		Exposed conduit holes due to open covers
Abbey Park H.S.	HB164	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Abbey Park H.S.	HB163	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Abbey Park H.S.	HB108	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Abbey Park H.S.	HB177	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Abbey Park H.S.	HBL213	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Abbey Park H.S.	HBL227	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Abbey Park H.S.	HB043	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Abbey Park H.S.	HB131	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Abbey Park H.S.	HB072	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Abbey Park H.S.	HB053	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Abbey Park H.S.	HB206	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Abbey Park H.S.	HBL224	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Captain R. Wilson P.S.	HB047	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Captain R. Wilson P.S.	HB106	EAST	7/23/2024	Evan Faubert	September 2024	Yes	Yes	WALLS	Level 1 - Approximately 40 square feet of wet drywall wall below north window and both sides of door. Approximately 20 square feet at south end junction.
Captain R. Wilson P.S.	HB065	EAST	7/23/2024	Evan Faubert	September 2024	No	Yes		Hole in cladding below window.
Captain R. Wilson P.S.	HB014	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Captain R. Wilson P.S.	HBL217	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Captain R. Wilson P.S.	HB174	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Captain R. Wilson P.S.	HB087	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Captain R. Wilson P.S.	HB162	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Captain R. Wilson P.S.	HB013	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL300	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL301	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL302	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO

David R. Williams P.S.	HBL303	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL304	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL305	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL306	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL307	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL308	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL309	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL310	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL311	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL320	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL321	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL322	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL323	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL324	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL325	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL326	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL327	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL328	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL329	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL330	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
David R. Williams P.S.	HBL331	EAST	7/25/2024	Evan Faubert	September 2024	No	No		NSMOMO
Emily Carr P.S.	HB084	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Emily Carr P.S.	HBL008	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Falgarwood P.S.	HB167	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Falgarwood P.S.	HB121	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Garth Webb S.S.	HBL080	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Garth Webb S.S.	HBL258	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Garth Webb S.S.	HB038	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Garth Webb S.S.	HB045	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Garth Webb S.S.	HBL005	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Garth Webb S.S.	HB090	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Garth Webb S.S.	HB052	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Garth Webb S.S.	HB076	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Garth Webb S.S.	HB100	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Garth Webb S.S.	HB135	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Garth Webb S.S.	HB091	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Garth Webb S.S.	HBL085	EAST	7/23/2024	Evan Faubert	September 2024	No	No		NSMOMO
Heritage Glen	HBL208	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
Heritage Glen	HBL268	EAST	7/30/2024	Evan Faubert	September 2024	No	Yes		Degraded caulking at door and broken floor tile.
Iroquois Ridge H.S.	HB145	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Iroquois Ridge H.S.	HB088	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Iroquois Ridge H.S.	HB202	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Iroquois Ridge H.S.	HB070	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Iroquois Ridge H.S.	HB209	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Iroquois Ridge H.S.	HBL264	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Iroquois Ridge H.S.	HB036	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Iroquois Ridge H.S.	HB034	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Iroquois Ridge H.S.	HB010	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Iroquois Ridge H.S.	HBL256	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
James W. Hill P.S.	HB086	EAST	7/26/2024	Evan Faubert	September 2024	No	Yes		Screwholes at door and east corner
James W. Hill P.S.	HB080	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
James W. Hill P.S.	HB099	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
James W. Hill P.S.	HB176	EAST	7/26/2024	Evan Faubert	September 2024	Yes	Yes	WALLS	Level 3 - 60 Square feet of wet drywall walls two feet at east and west walls.
James W. Hill P.S.	HB107	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Joshua Creek P.S.	HB085	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Joshua Creek P.S.	HB011	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Joshua Creek P.S.	HB077	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Joshua Creek P.S.	HB155	EAST	7/26/2024	Evan Faubert	September 2024	Yes	Yes	WALLS	Level 4 - Remove impacted walls on east west and south sides to 2 feet.

Joshua Creek P.S.	HB161	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Montclair P.S.	HBL299	EAST	7/30/2024	Evan Faubert	September 2024	No	Yes		Screwholes at corner cladding
Montclair P.S.	HBL298	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
Montclair P.S.	HBL210	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
New Central P.S.	HB079	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
New Central P.S.	HB104	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oakville Trafalgar H.S.	RM190	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oakville Trafalgar H.S.	RM191	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oakville Trafalgar H.S.	RM192	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oakville Trafalgar H.S.	RM193	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oakville Trafalgar H.S.	RM194	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oakville Trafalgar H.S.	RM189A	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oakville Trafalgar H.S.	RM189B	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oakville Trafalgar H.S.	RM195	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oakville Trafalgar H.S.	RM196	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oakville Trafalgar H.S.	RM197	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oakville Trafalgar H.S.	RM198	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oodenawi P.S.	HB058	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oodenawi P.S.	HB101	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oodenawi P.S.	HBL260	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oodenawi P.S.	HBL248	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oodenawi P.S.	HB171	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oodenawi P.S.	HB175	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oodenawi P.S.	HBL086	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oodenawi P.S.	HB067	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oodenawi P.S.	HB044	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oodenawi P.S.	HB094	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oodenawi P.S.	HBL214	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Oodenawi P.S.	HB096	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Pilgrim Wood P.S.	HBL243	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Pilgrim Wood P.S.	HBL200	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Pilgrim Wood P.S.	HB006	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Pilgrim Wood P.S.	HBL267	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Pilgrim Wood P.S.	HBL087	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Pilgrim Wood P.S.	HBL337	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Pilgrim Wood P.S.	HB040	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Pilgrim Wood P.S.	HB008	EAST	7/29/2024	Evan Faubert	September 2024	No	No		NSMOMO
Post's Corners P.S.	HBL102	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Post's Corners P.S.	HB180	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Post's Corners P.S.	HB129	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Post's Corners P.S.	HBL006	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Post's Corners P.S.	HBL218	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Post's Corners P.S.	HBL255	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Post's Corners P.S.	HBL211	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Post's Corners P.S.	HBL007	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Post's Corners P.S.	HB123	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Post's Corners P.S.	HB158	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Post's Corners P.S.	HBL269	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
Post's Corners P.S.	HBL268	EAST	7/26/2024	Evan Faubert	September 2024	No	No		NSMOMO
River Oaks P.S.	HBL294	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
River Oaks P.S.	HBL295	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
River Oaks P.S.	HBL314	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
River Oaks P.S.	HBL215	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
River Oaks P.S.	HBL081	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
River Oaks P.S.	HBL315	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
Sheridan	HBL108	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
W.H. Morden P.S.	HBL209	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
W.H. Morden P.S.	HB199	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO

W.H. Morden P.S.	HB200	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
W.H. Morden P.S.	HBL201	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
W.H. Morden P.S.	HBL250	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
W.H. Morden P.S.	HBL249	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
W.H. Morden P.S.	HB055	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
W.H. Morden P.S.	HB138	EAST	7/3/2024	Evan Faubert	September 2024	No	No		NSMOMO
West Oak P.S.	RM1	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
West Oak P.S.	RM2	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
West Oak P.S.	RM3	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
West Oak P.S.	RM4	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
West Oak P.S.	RM5	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
West Oak P.S.	RM6	EAST	7/30/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks North H.S.	HB149	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks North H.S.	HBL334	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks North H.S.	HBL333	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks North H.S.	HBL092	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks North H.S.	HBL093	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks North H.S.	HBL094	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks North H.S.	HBL095	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks North H.S.	HB060	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HBL018	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HBL017	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HBL016	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HB054	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HBL096	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HBL097	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HB042	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HB023	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HB205	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HB078	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HBL261	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HB130	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HB201	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HB112	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HB153	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO
White Oaks South H.S.	HBL009	EAST	7/12/2024	Evan Faubert	September 2024	No	No		NSMOMO